



2/27/2006 RE-ISSUED September 11, 2009

BEST TECHNOLOGY  
TOM DONAHOE  
75D GOLF PARKWAY  
MADISON WI 53704

~~PROMOLD & TOOL~~  
~~MIKE HORNBACK~~  
~~166 E ROCKFORD LANE~~  
~~LOUISVILLE KY 40216~~

Re: Description: **SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER\***  
Manufacturer: PROMOLD & TOOL  
Product Name: BEST GF10 GRAVITY FILTER  
Model Number(s): GF10-32  
(**> 1/32 IN. FILTRATION**; FILTER FLOW RATINGS: 2500 GALLONS PER DAY FLOW, 70 GALLONS PER MINUTE WHEN CLEAN, 46.9 GALLONS PER MINUTE WHEN 80% PLUGGED)  
Product File No: 20060035

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of FEBRUARY 2010.**

This approval is contingent upon compliance with the following stipulation(s):

- **Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.**
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- When this product is installed in an interior compartment, the discharge connection must be solvent cemented to a single four inch diameter schedule 40 PVC, plastic pipe (ASTM D-2665 or ASTM D-1785) which is solvent cemented to a four inch diameter schedule 40 PVC coupling encased in the interior wall.
- A manhole extending to grade must be provided over the filter.
- This product has BEST TECHNOLOGY embossed on the top of the filter plate.

This approval supersedes the approval issued on 2/27/2006 under product file number 20060035. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060035.

**\* This product type category has been changed to better reflect its use; it was previously approved as STA-sewage treatment apparatus; it is now listed as STAF- sewage treatment apparatus, effluent filter only.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov